

Kansas City, MO 64030

(816) 761-7476



DSDF (DH-98) CONVENTIONAL DUCT DETECTOR

•



STANDARD FEATURES

•

- Detects and limits the spread of smoke throughout building HVAC ducts
- Ability to interconnect (all relays operate wth a single alarm) up to 30 units using the same independent power supply
- · Compatible with building automation and fire alarm systems
- · Installs quickly and easily
- Interchangeable "Plug-In" photoelectric or ionization heads
- No screens or filters to clean
- Cover provides magnet window and placement guide for operational testing without disassembly
- Rugged gray steel back box with clear cover
- Accessories Remote power, remote alarm indication capability and remote, horn/piezo capability
- Meets UL268A Requirements

PRODUCT LISTINGS

Underwriters Laboratories 81383 CSFM # 3240-0410:155 FM # 3005751

SPECIFICATIONS

REMOTE INDICATION CAPABILITY (Refer to DH-98 Accessories Data Sheet for Specification) Power, Alarm, Horn/Piezo, Test **AIR VELOCITY** 300 to 4000 ft./min. AMBIENT TEMPERATURE 32°F to 120°F (0°C TO 49°C) HUMIDITY 10% to 85% Relative Humidity (non-condensing) HOUSING MATERIAL 18 G.A. steel backbox, clear plastic cover FINISH Grey Paint DIMENSIONS 91/8"l x 71/4"w x 21/4"h MAXIMUM NET WEIGHT 3 lbs. SAMPLING TUBES 2.5 FT., 5 ft. OR 10 ft.

115V AC, 24V AC/DC DETECTOR HEAD MODEL SLJ-24DH DETECTOR HEAD TYPE Conventional Photoelectric POWER REQUIREMENTS STANDBY 115V VAC – 14mA 24 VAC – 20mA 24 VDC – 13mA POWER REQUIREMENTS ALARM 115V VAC – 28mA 24 VAC – 95mA 24 VDC – 60mA

OPERATING VOLTAGE

ALARM CONTACTS 1 form "C" and 1 form "A" rated at 10 amps @ 115 V.A.C. DETECTION LOOP

1 Form A (1A)

TROUBLE CONTACTS 1 Form "C"

SENSITIVITY TEST METHOD Self Diagnostic Test

DESCRIPTION

The HOCHIKI AMERICA DH-98 (DSDF) Duct Smoke Detector provides early detection of smoke and products of combustion present in air moving through HVAC ducts in Commercial, Industrial and Residential applications. The DH-98 is designed to prevent the recirculation of smoke in areas by the air handling systems, fans and blowers. Complete systems may be shut down in the event of smoke detection. The HOCHIKI AMERICA DH-98-1 and the DH-98-P operate on 115 VAC, 24 VAC and 24 VDC and the DH-98-HVI and the DH-98-HVP operate on 230 VAC, 24 VAC and 24 VDC.

The DH-98 is designed and built to meet all local requirements, as well as the NFPA regulations regarding duct smoke detectors. Output terminals are provided for remote accessories such as a horn, strobe, remote status indicators and reset key switches or push buttons.

Air sampling is accomplished by two tubes which protrude into the duct. An exhaust tube of one standard length (7.5") is supplied in the installation kit with the smoke duct unit. Once the duct width has been determined the air intake sampling tubes must be ordered. Sampling tubes are supplied in three standard lengths 2.5 ft., 5 ft. and 10 ft. and cut to size to fit the duct. Mounting the duct smoke unit is accomplished by the use of a template and 4 sheet metal screws, which are provided. Mounting can be achieved with out the removal of the clear cover which is secured by 4 capture screws.


The compact DH-98 contains 3 sets of alarm contacts, 1 set of form "C" contacts rated at 10 amps, 1 set of form "A" contacts rated at 10 amps, 1 set of form "A" contacts rated at 1 amp. There is also 1 set of form "C" 10 amp trouble contacts for monitoring detector head removal, and the failure of the input supply voltage.


The pilot and alarm visual indicators provided on the front of the DH-98 duct unit, signal the operating status of the device. A manual test/reset switch is located along side the visual indicators. This switch can be defeated by cutting a jumper on the PCB.

ENGINEERING SPECIFICATIONS

Air duct smoke detectors shall be HOCHIKI AMERICA DH-98 Series. The detectors shall be listed by Underwriters Laboratories per UL 268A. The detectors shall operate at air velocities from 300 feet per minute to 4000 feet per minute. The detectors shall have the ability to interconnect up to 30 units using the same independent power supply. The duct detector housings shall be of metal construction and complete mechanical installation may be performed without removal of detector cover. Visual indication of alarm and power must be provided on detector front. A manual reset switch shall be located on front of the device. Detector heads shall not require additional filters or screens which must be maintained. The housing shall contain a detector base which will accept photoelectric or ionization detector heads. Terminal connections shall be of the screw type and be a minimum of#6 screw. Terminals shall be provided for remote pilot, remote alarm indication, strobe/horn and remote key switch. All wiring must comply with local codes and regulations.

WIRING DIAGRAMS





INTERCONNECT WIRING DIAGRAMS



3900 Dr. Greaves Rd. Kansas City, MO 64030 (816) 761-7476 FAX (816) 765-8955 www.ruskin.com